



Ref. Certif. No

NO129848

IEC SYSTEM FOR MUTUAL RECOGNITION OF TEST CERTIFICATES FOR ELECTRICAL EQUIPMENT (IECEE) CB SCHEME

CB TEST CERTIFICATE

Product

AC/DC-DC Power Shelf

Name and address of the applicant

Bel Fuse Inc.  
300 Executive Drive, Suite 300  
West Orange NJ 07052  
United States of America

Name and address of the manufacturer

Bel Fuse Inc.  
300 Executive Drive, Suite 300  
West Orange NJ 07052  
United States of America

Name and address of the factory

BPS Asia Pacific Electronics (Shenzhen) Co., Ltd.  
Building# 6, Nanming Road, Gongming Town Huahong Xintong Industrial Park  
Guangming District Shenzhen 518108  
China

Note: When more than one factory, please report on page 2

Additional Information on Page 2

Ratings and Principal characteristics

SPSTET4V3-02 with PSU (TET4000-48-069RAS510 / TET4000-48-069RAH series):  
Input: 3 Phase Wye, 3W+N+PE; Input Voltage: 200-277 / 346-480Vac; Input Current: 22A x 2,  
50/60Hz  
See additional information for more ratings.

Trademark /Brand (If any)



Customer's Testing Facility (CTF) Stage used

CTF Stage 3

Model/Type Ref

SPSTET4V3-02

Additional information (If necessary may also be reported on Page 2)

Additional Information on Page 2

A sample of the product was tested and found to be in conformity with

IEC 62368-1:2018

As shown in the Test Report Ref. No. which forms part of this Certificate

REP031994

This CB Test Certificate is issued by the National Certification Body



Philip Pedersen vei 11,  
NO-1366 Lysaker, Norway  
Date: 04-04-2024

Signature: Okhyun Jeon  
Certification department



Ref. Certif. No

NO129848

### Additional Information (if necessary)

SPSTET4V3-02 with PSU (TET4000-48-069RAS510 / TET4000-48-069RAH series):

Input: 3 Phase Delta,3W+PE  
Input Voltage: 200-277Vac  
Input Current: 38A x 2, 50/60Hz

Input: Single Phase  
Input Voltage: 200-277Vac  
Input Current: 22A x 6, 50/60Hz

Input: HVDC  
Input Voltage: 240-380Vdc  
Input Current: 18A x 6

DC Output: V1: 48-58VDC, 500A Max.;  
V2: 12VDC, 5A; Max. DC output power: 24060W

SPSTET4V3-02 with PSU (TET4800-48-069RA):

Input: 3 Phase Wye, 3W+N+PE  
Input Voltage: 200-277 / 346-480Vac  
Input Current: 26A x 2, 50/60Hz

Input: 3 Phase Delta,3W+PE  
Input Voltage: 200-277Vac  
Input Current: 46A x 2, 50/60Hz

Input: Single Phase  
Input Voltage: 200-277Vac  
Input Current: 26A x 6, 50/60Hz

Input: HVDC  
Input Voltage: 240-380Vdc  
Input Current: 22A x 6

DC Output: V1: 48-58VDC, 600A Max.;  
V2: 12VDC, 4A; Max. DC output power: 28848W

May be followed by alpha numeric characters indicating non-safety critical options.



Philip Pedersen vei 11,  
NO-1366 Lysaker, Norway

Date: 04-04-2024

Signature: Okhyun Jeon  
Certification department




Ref. Certif. No

NO129849

IEC SYSTEM FOR MUTUAL RECOGNITION OF TEST CERTIFICATES FOR ELECTRICAL EQUIPMENT (IECEE) CB SCHEME

CB TEST CERTIFICATE

<b>Product</b>	AC/DC-DC Power Shelf
<b>Name and address of the applicant</b>	Bel Fuse Inc. 300 Executive Drive, Suite 300 West Orange NJ 07052 United States of America
<b>Name and address of the manufacturer</b>	Bel Fuse Inc. 300 Executive Drive, Suite 300 West Orange NJ 07052 United States of America
<b>Name and address of the factory</b>	BPS Asia Pacific Electronics (Shenzhen) Co., Ltd. Building# 6, Nanming Road, Gongming Town Huahong Xintong Industrial Park Guangming District Shenzhen 518108 China
<i>Note: When more than one factory, please report on page 2</i>	<input type="checkbox"/> Additional Information on Page 2
<b>Ratings and Principal characteristics</b>	SPSTET4V3-01, SPSTET4V3-01C with PSU (TET4000-48-069RAS510 / TET4000-48-069RAH Series): Input: 3 Phase Wye, 3W+N+PE; Input Voltage: 200-277 / 346-480Vac; Input Current: 32A x 2, 50/60Hz; Aux. Output: 200-277Vac, 50/60Hz, 10A x2 See additional information for more ratings.
<b>Trademark /Brand (If any)</b>	
<b>Customer's Testing Facility (CTF) Stage used</b>	CTF Stage 3
<b>Model/Type Ref</b>	SPSTET4V3-01, SPSTET4V3-01C
<b>Additional information (If necessary may also be reported on Page 2)</b>	<input checked="" type="checkbox"/> Additional Information on Page 2
<b>A sample of the product was tested and found to be in conformity with</b>	IEC 62368-1:2018
<b>As shown in the Test Report Ref. No. which forms part of this Certificate</b>	REP031994

This CB Test Certificate is issued by the National Certification Body



Philip Pedersen vei 11,  
NO-1366 Lysaker, Norway  
Date: 04-04-2024

Signature: Okhyun Jeon  
Certification department



Ref. Certif. No

NO129849

### Additional Information (if necessary)

SPSTET4V3-01, SPSTET4V3-01C with PSU (TET4000-48-069RAS510 / TET4000-48-069RAH Series):

Input: 3 Phase Delta, 3W+PE

Input Voltage: 200-277Vac

Input Current: 48A x 2, 50/60Hz

Aux. Output: 200-277Vac, 50/60Hz, 10A x2

Input: Single Phase

Input Voltage: 200-277Vac

Input Current: 32A x 6, 50/60Hz

Aux. Output: 200-277Vac, 50/60Hz, 10A x2

Input: HVDC

Input Voltage: 240-380Vdc

Input Current: 28A x 6

Aux. Output: 240-380Vdc, 10A x2

DC Output: V1: 48-58VDC, 500A Max.;

V2: 12VDC, 5A; Max. DC output power: 24060W

SPSTET4V3-01 SPSTET4V3-01C with PSU (TET4800-48-069RA Series):

Input: 3 Phase Wye, 3W+N+PE

Input Voltage: 200-277 / 346-480Vac

Input Current: 36A x 2, 50/60Hz

Aux. Output: 200-277Vac, 50/60Hz, 10A x2

Input: 3 Phase Delta, 3W+PE

Input Voltage: 200-277Vac

Input Current: 56A x 2, 50/60Hz

Aux. Output: 200-277Vac, 50/60Hz, 10A x2

Input: Single Phase

Input Voltage: 200-277Vac

Input Current: 36A x 6, 50/60Hz

Aux. Output: 200-277Vac, 50/60Hz, 10A x2

Input: HVDC

Input Voltage: 240-380Vdc

Input Current: 32A x 6

Aux. Output: 240-380Vdc, 10A x2

DC Output: V1: 48-58VDC, 600A Max.;

V2: 12VDC, 4A; Max. DC output power: 28848W

May be followed by alpha numeric characters indicating non-safety critical options.



Philip Pedersen vei 11,  
NO-1366 Lysaker, Norway

Date: 04-04-2024

Signature: Okhyun Jeon  
Certification department